




**FRONT ELEVATION LESS FRONTS**



**FRONT ELEVATION ENCLOSED**



**SECTION A-A**



**ONE LINE DIAGRAM**


SYSTEM	CATALOG #	INTERIOR DWG. #	WITHSTAND RATING	SHIPPING WEIGHT
3 $\phi$ 3W *	CT123-FECD	03340.02	100,000A	300
3 $\phi$ 4W	CT124-FECD	03340.03	100,000A	320

\* CHECK WITH UTILITY CO. FOR SUITABILITY OF THIS EQUIPMENT

**NOTES:**

THIS EQUIPMENT IS FURNISHED IN TYPE 3R ALUMINUM ENCLOSURES.

THE METERING TRANSFORMER CABINET IS LISTED BY UNDERWRITERS LABORATORIES INC. AND HAS AN UNPROTECTED SHORT CIRCUIT CURRENT RATING OF 100,000 R.M.S. SYM. AMPERES.



1200A 600V CURRENT TRANSFORMER CABINETS FIRST ENERGY CORP.	CT-03340.23 6/7/93 BE 3/23/06 KE 6/21/07 KE 7/23/07 KE
ERICKSON ELECTRICAL EQUIP. CO. 475 BONNIE LANE ELK GROVE VILLAGE, IL 60007	